

# Monthly Report

Wastewater

January 2016

## **A. Treatment – Operation:**

1. Operated treatment plant to comply with State and Federal regulations.
2. Performed daily, weekly, and monthly maintenance as recommended in the manufacturer's manuals.
3. Treated average of 907,000 gallons/day of wastewater.
4. Received and treated 11,350 gallons of hauled waste.

## **B. Collection – Operation:**

1. 3 man hours used to perform 4 line locates.

## **C. Collection – Corrective:**

1. 4 man hours used to respond to a backup complaint at 840 Stout. The flow in the main was good, but hydraulically cleaned it for good measure, and removed a few roots. Homeowner was still having problems. Video inspected the main and tap, and it was determined to be homeowner's issue.
2. 2 man hours used to respond to a backup complaint at 700 W. Victory Way. Found a significant amount of grease in manhole (from complainant's restaurant). The main was hydraulically cleaned and the manhole was vacuumed. It was determined to be the business owner's issue.
3. 2 man hours used to respond to a backup complaint at 889 Barclay. The main was hydraulically cleaned and a partial blockage was found. The blockage was removed and flow returned to normal for the homeowner. There was no damage to the property.
4. 2 man hours used to respond to a backup complaint at 839 Rose St. Sewage had backed up into the homeowner's basement. The main was found to be flowing well, but hydraulically cleaned it for good measure. It was determined to be the homeowner's issue.
5. 2 man hours used to respond to a backup complaint at 1107 Washington. The main was found to be flowing well, but hydraulically cleaned it for good measure. It was determined to be the homeowner's issue.

## **D. Other:**

1. Assisted other departments as needed.
2. Assisted local plumbers as needed.
3. Analyzed Maybell's monthly samples.