

Monthly Report

Wastewater

March 2016

A. Treatment – Operation:

1. Operated treatment plant to comply with State and Federal regulations.
2. Performed daily, weekly, and monthly maintenance as recommended in the manufacturer's manuals.
3. Treated average of 1,081,000 gallons/day of wastewater.
4. Received and treated 12,900 gallons of hauled waste.

B. Collection – Operation:

1. 6.5 man hours used to perform 8 line locates.
2. 24 man hours used to hydraulically clean 3575 ft. of pipe as part of a routine maintenance program.
3. 2 man hours used to hydraulically clean 600 ft. of pipe as part of annual cleaning program.
4. Replaced level transducer at Burrows Lift Station.

C. Collection – Corrective:

1. 4 man hours used to respond to a backup complaint at 315 Tucker. The main was hydraulically cleaned and a blockage of approximately 50 feet in length, of ice (frozen sewer), was found in the main. The main was cleaned until all of the ice was gone and the flow was returned to normal. No damage to property was reported.
2. 1 man hour used to respond to a backup complaint in the 500 block of Yampa. The main was flowing well. It was determined to be the business owner's issue.

D. Other:

1. Assisted other departments as needed.
2. Assisted local plumbers as needed.
3. Analyzed Maybell's monthly samples.