

Monthly Report

Wastewater

May 2016

A. Treatment – Operation:

1. Operated treatment plant to comply with State and Federal regulations.
2. Performed daily, weekly, and monthly maintenance as recommended in the manufacturer's manuals.
3. Treated average of 1,021,000 gallons/day of wastewater.
4. Received and treated 5450 gallons of hauled waste.
5. Aerators were put into operation in the southeast treatment lagoon.

B. Collection – Operation:

1. 4 man hours used to perform 7 line locates.
2. 24 man hours used to hydraulically clean 3575 ft. of pipe as part of a routine maintenance program.

C. Collection – Corrective:

1. 1 man hour used to respond to a backup complaint at 693 Yampa. Homeowner said drains were backing up. Main was inspected and found to be flowing properly. It was determined to be the homeowner's issue.
2. 1 man hour used to respond to a backup complaint at 537 School St. Homeowner stated that nothing in the house would drain and the toilet wouldn't flush. Upper and lower manholes were inspected and found to be flowing well. It was determined to be the homeowner's issue.

D. Other:

1. Assisted other departments as needed.
2. Assisted local plumbers as needed.
3. Analyzed Maybell's monthly samples.