

Monthly Report

Wastewater

July 2016

A. Treatment – Operation:

1. Operated treatment plant to comply with State and Federal regulations.
2. Performed daily, weekly, and monthly maintenance as recommended in the manufacturer's manuals.
3. Treated average of 869,000 gallons/day of wastewater.
4. Received and treated 7,600 gallons of hauled waste.

B. Collection – Operation:

1. 6.5 man hours used to perform 8 line locates.
2. 26 man hours used to apply herbicide to 7473 ft. of pipe as part of the annual herbicide application project.
3. Work continues on the Lariat Lift Station project. It is nearing completion.

C. Collection – Corrective:

1. 2 man hours used to respond to a backup complaint at 556 Barclay. Sewage was backing up into basement. Inspection of upstream and downstream manholes showed standing water. The main was hydraulically cleaned and unknown obstruction was cleared, restoring proper flow to main. The basement was inspected and no visible damage was observed.

D. Other:

1. Assisted other departments as needed.
2. Assisted local plumbers as needed.
3. Assisted contractors and engineers on our projects as needed.
4. Analyzed Maybell's monthly samples.