

Monthly Report

Wastewater

August 2016

A. Treatment – Operation:

1. Operated treatment plant to comply with State and Federal regulations.
2. Performed daily, weekly, and monthly maintenance as recommended in the manufacturer's manuals.
3. Treated average of 838,000 gallons/day of wastewater.
4. Received and treated 19,800 gallons of hauled waste.
5. Sludge is dry and is being piled in preparation for land application in September.

B. Collection – Operation:

1. 8.5 man hours used to perform 13 line locates.
2. 15.5 man hours used to apply herbicide to 3760 ft. of pipe as part of annual herbicide application project.
3. 24 man hours used to hydraulically clean 3575 ft. of pipe as part of routine (every 5 weeks) maintenance.
4. Lariat Lift Station project is complete and is in operation.

C. Other:

1. Assisted other departments as needed.
2. Assisted local plumbers as needed.
3. Assisted contractors and engineers on our projects as needed.
4. Analyzed Maybell's monthly samples.
5. Analyzed sludge and soil in preparation for land application in September.